

# Certificate

PROFIBUS Nutzerorganisation e.V. grants to

**AUCOM ELECTRONICS LTD.**

**123 Wrights Road, Middleton, 8024 Christchurch, New Zealand**

the Certificate No: **Z10619** for the PROFINET IO Device:

**Model Name: PROFINET Interface**  
**Revision: SW/FW: V1.4.17; HW: 04**  
**Identnumber: 0x0253; 0x010D**  
**GSD: GSDML-V2.3-AUCOM-NIC 50-RE PNS-20130813.xml**  
**DAP: DAP1, 0x00000101**

This certificate confirms that the product has successfully passed the certification tests with the following PROFINET scope:

|  |  |
|--|--|
| <input checked="" type="checkbox"/> <b>Hardware</b>            | Auto_Negotiation, Auto_Polarity, Auto_Crossover    |
| <input checked="" type="checkbox"/> <b>Conformance Class B</b> | RT_CLASS_1, RTA, LLDP, SNMP, MIB-II, LLDP-MIB, FSU |

**Test Report Number: PNE131757E01**  
**Authorized Test Laboratory: Phoenix Testlab GmbH, Blomberg, Germany**

The tests were executed in accordance with the following documents:  
 "Test Specifications for PROFINET IO devices, Version 2.2.4 from December 2010" and  
 "Test Cases for PN-Tester for PROFINET IO devices, Version 2.2.4.16.21".

This certificate is granted according to the document:  
 "Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by August 14, 2019 the certificate is valid for life.




(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.



(Karsten Schneider)

(K.-P. Lindner)